



SHEAR WALL TABLE			
TYPE	WIND	SEISMIC	DESCRIPTION
△	305	260	3/8" APA RATED SHEATHING ONE FACE W/ 8d COMMON NAILS @ 6" OC. EDGE AND 12" OC. FIELD. 5/8" DIAM. ANCHOR BOLTS @ 48" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS.
△	350	350	3/8" APA RATED SHEATHING ONE FACE W/ 8d COMMON NAILS @ 4" OC. EDGE AND 12" OC. FIELD. 5/8" DIAM. ANCHOR BOLTS @ 36" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS.
△	600	490	3/8" APA RATED SHEATHING ONE FACE W/ 8d COMMON NAILS @ 3" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIAM. ANCHOR BOLTS @ 14" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS.
△	600	600	3/8" APA RATED SHEATHING ONE FACE W/ 8d COMMON NAILS @ 2" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIAM. ANCHOR BOLTS @ 14" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS. PROVIDE 3X PT DF SILL PLATE.
△	750	640	3/8" APA RATED SHEATHING ONE FACE W/ 8d COMMON NAILS @ 2" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIAM. ANCHOR BOLTS @ 24" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS. PROVIDE 3X PT DF SILL PLATE.
△	830	760	3/8" APA RATED SHEATHING TWO FACE W/ 8d COMMON NAILS @ 4" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIAM. ANCHOR BOLTS @ 24" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS. PROVIDE 3X PT DF SILL PLATE.
△	1240	980	3/8" APA RATED SHEATHING TWO FACE W/ 8d COMMON NAILS @ 3" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIAM. ANCHOR BOLTS @ 20" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS. PROVIDE 3X PT DF SILL PLATE.
△	1530	1280	3/8" APA RATED SHEATHING TWO FACE W/ 8d COMMON NAILS @ 2" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIAM. ANCHOR BOLTS @ 14" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS. PROVIDE 3X PT DF SILL PLATE.
△	970	770	15/32" APA RATED SHEATHING ONE FACE W/ 10d COMMON NAILS @ 2" OC. EDGE AND 12" OC. FIELD. INSTALL MIN. 3"x NOMINAL FRAMING MEMBERS @ ADJOINING PANEL EDGES W/ STAGGERED NAILING. 5/8" DIA. ANCHOR BOLTS @ 22" OC. MAX. HOLDOWNS AS SPECIFIED IN CALCULATIONS. PROVIDE 3X PT DF SILL PLATE.

SIMPSON HOLD-DOWN TABLE			
TYPE	WIND	SEISMIC	DESCRIPTION
◇	1705	1705	CS16 STRAP 14" MINIMUM END SPAN, CLEAR SPAN VARIES. ATTACH TO 2"x FRAMING MEMBERS AT SHEARWALL AND FRAMING BELOW, FLOOR FRAMING OR SHEAR WALL.
◇	3410	3410	(2) CS16 STRAPS, 14" MINIMUM END SPAN, CLEAR SPAN VARIES. ATTACH TO 4"x FRAMING MEMBERS AT SHEARWALL.
◇	4585	4585	CMSTC16 STRAP 23" MINIMUM END SPAN, CLEAR SPAN VARIES. ATTACH TO 4"x FRAMING MEMBERS AT SHEARWALL.
◇	5860	5860	MSTC66 FLOOR TIE, 18" MAXIMUM CLEAR SPAN, ATTACH TO 4"x FRAMING MEMBERS AT SHEARWALL.
◇	2940	2940	STDH14 TO 4"x 4" POST WITH (20) 16d SINKER NAILS
◇	3815	3815	STDH14 TO 4"x 4" POST WITH (24) 16d SINKER NAILS
◇	3072	3072	HU2 HOLD-DOWN TO 4X4 POST MIN. WITH SSB20 ANCHOR.
◇	4565	4565	HU4 HOLD-DOWN TO 4X4 POST MIN. WITH SSB24 ANCHOR.
◇	5645	5645	HU5 HOLD-DOWN TO 4X4 POST MIN. WITH SSB24 ANCHOR.
◇	6970	6970	HU8 HOLD-DOWN TO 4X4 POST MIN. WITH SSB34 ANCHOR.
◇	9535	9535	HU11 HOLD-DOWN TO 6X POST MIN. WITH SSB34 ANCHOR.
◇	9540	9540	HU10A HOLD-DOWN TO 4X4 POST MIN. WITH SSB34 ANCHOR.
◇	11080	11080	HU14A HOLD-DOWN TO 4X6 POST MIN. WITH 1" A307 THREADED ROD
◇	15305	15305	HU15 HOLD-DOWN TO 6X6 POST MIN. WITH 1 1/4" A307 THREADED ROD

SEE SHEET S1 FOR GENERAL NOTES.

DATE	REVISIONS

ENGINEER: **Paulo Ibanez P.E.**  
 7111 Aspen View Ct.  
 Citrus Heights, CA 95621  
 Ph. (916) 524-3052  
 Off. Fax (916) 722-3579

DESIGNER: **d. i. poitts drafting services**  
 Deanna Poitts  
 7227 Main Ave.  
 Orangevale, Ca. 95662  
 Off. Fax (916) 988-7368

PROJECT: NEW CONSTRUCTION  
**PALM DRIVE**  
 COUNTY OF SACRAMENTO, CA. A.P.N. - 273-0400-003-0000  
 OWNER: **SCOTT & YVETTE GORDON**  
 6435 ORANGEHILL LANE CARMICHAEL, CA. 95608  
 PH. (916) 524-1833

**STRUCTURAL UPPER FLOOR PLAN/TABLES**

DATE: 6-25-14  
 DRAWN: dlp  
 SCALE: 1/4" = 1'-0"  
 JOB#: 14-723  
 SHEET: **S2**

